





Contrasemneaza, secretar general comuna
 Gherasim Popina

Presedinte de sedinta
 Consilier, Hajasan Dan-Tonel

crt.	maxima	determinare
1.	temperatura	40 °C
2.	pH	6,5-8,5 SR ISO 10523:97
3.	Materii in suspensie	350 mg/dm ³ STAS 6953:81
4.	Substante extractibile cu solventi organici	30 mg/dm ³ SR 7587:96
5.	Fenoli antrenabili cu vapori de apa (C ₆ H ₅ OH)	30 mg/dm ³ STAS7167:92
6.	Detergenti sintetici biodegradabili	25 mg/dm ³ SR ISO 7875/1,2:96
...	indicatori	considerati
	alti	esentiali